

Model DV-5A

File Number: EX6404

COMPANY

TYCO FIRE & BUILDING PRODUCTS

1467 ELMWOOD AVE
CRANSTON, RI 02910-3849 United States

MODEL INFO

DV-5A

GENERAL						
Sprinkler System Type	Body Type	Nominal Pipe Size, NPS	End Configuration	Max Rated Pressure, psig (kPa)	Trim Configuration Type	Installed Position
Deluge sprinkler system	Globe	1-1/2, 2	Grooved, Threaded	300 (2068)	Dry pilot, Wet pilot, Electric Actuation	Vertical
Deluge sprinkler system	Globe	3, 4, 6, 8	Flanged, Grooved, Flanged by Grooved	300 (2068)	--	Vertical
Deluge sprinkler system	Globe	165.1 mm	Grooved	300 (2068)	--	Vertical
Deluge sprinkler system	Globe	2	Grooved, Threaded	300 (2068)	--	Vertical
Deluge sprinkler system	Globe	3, 4, 6, 8	Flanged, Grooved, Flanged by Grooved	300 (2068)	--	Vertical
Deluge sprinkler system	Globe	165.1 mm	Grooved	300 (2068)	--	Vertical
Deluge sprinkler system	Globe	3, 4, 6, 8	Flanged, Grooved, Flanged by Grooved	250 (1723)	--	Vertical

GENERAL

Sprinkler System Type	Body Type	Nominal Pipe Size, NPS	End Configuration	Max Rated Pressure, psig (kPa)	Trim Configuration Type	Installed Position
Deluge sprinkler system	Globe	165.1 mm	Grooved	250 (1723)	--	Vertical
Preaction sprinkler system	Globe	1-1/2, 2	Grooved, Threaded	300 (2068)	--	Vertical
Preaction sprinkler system	Globe	3, 4, 6, 8	Flanged, Grooved, Flanged by Grooved	300 (2068)	--	Vertical
Preaction sprinkler system	Globe	165.1 mm	Grooved	300 (2068)	--	Vertical
Preaction sprinkler system	Globe	1-1/2, 2	Grooved, Threaded	300 (2068)	--	Vertical
Preaction sprinkler system	Globe	3, 4, 6, 8	Flanged, Grooved, Flanged by Grooved	300 (2068)	--	Vertical
Preaction sprinkler system	Globe	165.1 mm	Grooved	300 (2068)	--	Vertical

GENERAL

Installation Limitations

End configurations are intended to be installed on systems not exceeding end configurations' working capabilities.

For accessories used with these valves, see certifications under Accessories for Special Systems (VLTR).

All trim configuration types shall include a manual release. Height of pilot line above valve limited as shown in the installation instructions.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."

