# UL Product iQ®



## Model TJPX-300

File Number: EX26547

#### **COMPANY**

### **TYCO FIRE & BUILDING PRODUCTS**

1467 ELMWOOD AVE CRANSTON, RI 02910-3849 United States

#### **MODEL INFO**

**TJPX-300** 

GENERAL					
Pattern	Size, in.	<b>End Configuration</b>	Rated Pressure, psig (kPa)		
NRS	2-1/2, 3, 4, 5, 6, 8, 10, 12	F by F,G by G,F by G	300 (2068)		

NOTES				
Notes				
NRS valve provided wi	th a Post Indicator Flange	2		

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."